

- Ordering example for the replacement requirement -
The most important data which you should know about ordering in case of replacement.

Labels until 2019

1. **2.**



KRAUS & NAIMER
 MADE IN GERMANY
KG64 CE


MAN. MTR. MOTOR CONTROLLER IEC60947-3, EN60947-3, VDE0660-107
 MOTOR 120V 240V 480V 600V 50Hz 220V 380V 690V
 3PH -HP 5 10 20 20 Iu=Ith=AC-21A 40A 63A
 1PH -HP 2 5 10 10 AC-23A 3ph 11kW 22kW 18.5kW
 60 AMP. LISTED 77B7 UL 13002 AC-3 3ph 11kW 18.5kW 15kW
 600 VAC



DES
F66521/022
B T203/01

CCC GB14048.3 A008316

Labels from 2020 on



MAN. MTR. CNTLR.

VOLTS	120	240	480	600
MOTOR - HP 3ph	5	15	25	30
MOTOR - HP 1ph	2	5	10	10
GENERAL USE	42A 600V A.C.			

SUITABLE AS MOTOR DISCONNECT

LISTED 77B7 UL 13002 A008316 GB/T14048.3

IEC60947-3 / EN60947-3 / VDE0660-107

50/60Hz	220V	380V	660V
	240V	440V	690V
Iu = Ith = AC-21A	40A	40A	40A
AC-23A kW 3ph	7,5	15	15
AC-3 kW 3ph	7,5	11	11

Kraus & Naimer
KG11B-303
DE20W91119/900
 MADE IN GERMANY

CE EAC

If the information is incomplete or not available, we ask for meaningful photos of the switching device.