

CH11B

Type Size: S1

Classification Contact: H-Bridge

Classification Contact Mat: Gold plated Classification Terminal: Screw terminal

IEC 60947-3 EI	N 60947-3, VD	E 0660 Teil 10	07						
Rated insulation vo	Itage Ui	_		1/04	00 40/00	_		_	
				Voltage	e (V) AC / DC 600 50/60Hz/DC				
Pated impulse with	stand voltage Uimp				000 50/00HZ/DC				
Voltage (kV)	Overvoltage cated		ollution a	legree Supply s	vstem				Function
6	III	3			· lines with grounded co	mmon neutral t	ermination		Switch
Rated uninterrupted				valia 101	mico mai groundou oc	THE TOTAL TOTAL CO.	.commutation		omton.
Current (A)		temperature (°C)		Peak temperature (°C)	additional requiremen	rts			
6		55		60	Ambient temperature	+55°C during 2	4 hours with peal	ks up to +60°C	
Conventional enclo	sed thermal current	t Ithe							
Current Amb	oient temperature (°C)	Peak temperatur	re (°C)	Additional requirements		No. o	of stages (from - to)	Mounting	Mounting size
, ,	` ′			Ambient temperature +35	°C during 24 hours with		10)		
6	35		40	peaks up to +40°C	C during 24 nours with			-	
Rated operational c	urrent le								
Utilization category						Voltage (V)			Current (A
AC-21A						1			
AC-21A						6			
AC-21A						12			
AC-21A						24			
AC-21A						48			0,8
AC-21A						60			0,7
AC-21A						110			0,4
AC-21A						240			0,2
AC-21A						300			0,1
AC-21A						440			0,1
AC-21A						500			0,0
AC-21A						600			0,0
Max. Fuse rating IE	С								
Fuse characteristic						N	o. of Fuses		Current (A
gG							1		
UL60947-4-1,	UL508								
Rated insulation vo									
Rateu ilisulation voi	itage of			Voltage	e(V) AC/DC				
					300 AC				
Rated thermal curre	ent				710				
		Curre	ent (A)		Ambient te	mperature (°C)	Additional Text		
			6			0 - 40	-		
004									
CSA									
Rated insulation vol	Itage Ui								
				Voltage	e(V) AC/DC				
					300 AC				
Rated thermal curre	ent								
		Curre	ent (A)		Ambient te	mperature (°C)	Additional Text		
			6			0 - 40	-		
GENERAL TEC	HNICAL INFOR	RMATION							
Dotad about time									
Rated short-time wi	itiistanu current icw			Time	a (c)				Current (A





Size of conductor				
composition of conductor	Min. / Max. value	No. of conductor per terminal	Cross section (mm²) or (AWG/kcmil)	Material of the wire
Flexible wire	Max.	2	AWG 12	Copper
Flexible wire	Max.	2	2.5mm²	Copper
Single-core or stranded wire	Max.	2	AWG 10	Copper
Single-core or stranded wire	Max.	2	4mm²	Copper
Flexible wire with ferrule according to DIN 46228	Max.	2	2.5mm²	Copper
Recommended screw driver				
Type of screw driver		Value		
Cross Screwdriver		PH1		
Slot screwdriver according to DIN 5264		0,8x4		
Tightening torque of screws				
	tightening torque (i	Nm)		tightening torque (lb-in)
		1		9

Approbations Specification	
Specification	Marking
EAC	ERC
CE marking	C€
UK Directives	UK CA

IEC 60947-3; EN 60947-3; VDE 0660 Teil107

IEC 60947-3
EN 60947-3

UL 60947-4-1; CSA C22.2 No. 60947-4-1





Power loss per pole

CSA C.22.2 No.14

Power (W)

Conditions during transport a	and storing	
	Minimum temperature (°C)	Maximum temperature (°C) additional requirements
	-40	85 In case of temperatures below -5°C no shock load permissi
Shock / Vibration		
Type of oscillation		Values
Resistance to shock		min. 5g, 30ms
Resistance to vibration		IEC 61373 (1999) Category 1, Class B
General Information		
Text		

Text

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.
- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
- After wiring, ALL terminal screws must be tightened to the specified torque values.
- The protection class of the selected mounting type may vary if optional extras are used.
- Do not lubricate or treat contacts.
- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.
- After installation of the switches the spacings between the terminals must be sufficient to fulfill the requirement of the applicable standards.

Operating temperature

Min. Temperature [°C] Max. Temperature [°C]

-25 60