



KG80CT

Type Size: S2 Classification Contact: Rigid contact bridge Classification Contact Mat: Silver Classification Terminal: Screw terminal

Sample image

IEC 60947-3 EN 60947-3, VDE 0660 Teil 107

		,						
Rated insula	tion voltage Ui	i						
				Voltage	(V) AC/DC			
				(590 AC			
Rated impuls	se withstand v	oltage Uimp						
Voltage	e (kV) 🛛 Overv	oltage categ	ory Pollution	degree Supply sy	/stem			Function
	6 III		3	Valid for	lines with grounded corr	nmon neutral termination		Switch / Switch disconnector
Rated uninte	rrupted curren	nt lu/lth						
Current (A	4)	Ambient	temperature (°C)	Peak temperature (°C)	additional requirements	3		
8	80		50	55	Ambient temperature +	50°C during 24 hours with pea	ks up to +55°C	
Conventiona	I enclosed the	rmal current	Ithe					
Current (A)	Ambient ter	nperature (°C)	Peak temperature (°C)	Additional requirements		No. of stages (from - to)	Mounting	Mounting size
80		35	40	Ambient temperature +35° peaks up to +40°C	C during 24 hours with	-	-	
Rated operat	tional current l	е						
Utilization ca	tegory					Voltage (V)		Current (A)
AC-20A						690		80
AC-21A						20 - 690		80
AC-22A						220 - 500		80
AC-22A						660 - 690		65
Rated operat	tional power							
Utilization ca	tegory			Voltage (V)	No. of phases	No.	of poles	Power (kW)
AC-3				220 - 240	3		3	15
AC-3				380 - 440	3		3	22
AC-3				500 - 500	3		3	30
AC-3				660 - 690	3		3	18,50
AC-23A				220 - 240	3		3	18,50
AC-23A				380 - 440	3		3	30
AC-23A				500 - 500	3		3	37
AC-23A				660 - 690	3		3	22
Max. Fuse ra	ating IEC							
Fuse charact	eristic					No. of Fuses		Current (A)
gG						1		80
UL60947	-4-1 , UL50	8						
Rated insula	tion voltage Ui							
				Voltage	(V) AC/DC			
					500 AC			
Rated therm	al current				-			
			Current (A)		Ambient tem	perature (°C) Additional Text	t	
			80			0-40		

General Information Text

- The operating handle and position indicating means to be used with these manual motor controllers should be provided from the manufacturer, or the operating handle and position indicating means to be used should have been previously evaluated in combination with the manual motor controllers.

- When intended for use as a motor disconnector the device shall be provided with a method of being locked in the OFF-position.

GENERAL TECHNICAL INFORMATION Tightening torque of screws tightening torque (Nm) tightening torque (Nm) tightening torque (lb-in) 3 27



Rated short-time withstand current Icw

	Current (A)			
		1		1600
Size of conductor				
composition of conductor	Min. / Max. value	No. of conductor per terminal	Cross section (mm²) or (AWG/kcmil)	Material of the wire
Flexible wire	Max.	1	35mm²	Copper
Flexible wire	Max.	1	AWG 2	Copper
Single-core or stranded wire	Min.	1	AWG 10	Copper
Single-core or stranded wire	Max.	1	AWG 1/0	Copper
Single-core or stranded wire	Max.	1	50mm ²	Copper
Flexible wire with sleeve	Max.	1	35mm²	Copper

Approbations		
Specification		Marking
CE marking		CE
UK Directives		
IEC 60947-3; EN 60947-3; VDE 0660 Teil107		IEC 60947-3 EN 60947-3
UL 60947-4-1; CSA C22.2 No. 60947-4-1		c Uus LISTED7787
Power loss per pole		
		Power (W)
		1,70
Conditions during transport and storing		
Minimum temperature (°C)	Maximum temperature (°C)	additional requirements
-40	85	In case of temperatures below -5°C no shock load permissible
Shock / Vibration		
Type of oscillation	Values	
Resistance to vibration	Min. 4g, 2-100Hz, 1,6mm	
Resistance to shock	min. 6g, 6ms	

General Information Text

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.

- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.

- After wiring, ALL terminal screws must be tightened to the specified torque values.

- The protection class of the selected mounting type may vary if optional extras are used.

- Do not lubricate or treat contacts.

- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.

- The "ON" and "OFF" position may be marked using the symbols "I" and "O" according IEC60417, Symbols 5007 and 5008.

Operating temperature

Min. Temperature [°C]	Max. Temperature [°C]
-5	55