



Sample image

KH32

Type Size: S1
Classification Contact: Rigid contact bridge
Classification Contact Mat: Silver
Classification Terminal: Screw terminal
IEC 60947-3 EN 60947-3, VDE 0660 Teil 107

Rated insulation voltage Ui	
Voltage (V)	AC / DC
800	AC

Rated impulse withstand voltage Uimp				
Voltage (kV)	Overvoltage category	Pollution degree	Supply system	Function
6	III	3	Valid for lines with grounded common neutral termination	Switch / Switch disconnecter

Rated uninterrupted current Iu/Ith			
Current (A)	Ambient temperature (°C)	Peak temperature (°C)	Additional requirements
32	50	55	Ambient temperature +50°C during 24 hours with peaks up to +55°C

Conventional enclosed thermal current Ithe						
Current (A)	Ambient temperature (°C)	Peak temperature (°C)	Additional requirements	No. of stages (from - to)	Mounting	Mounting size
32	35	40	Ambient temperature +35°C during 24 hours with peaks up to +40°C	--	--	--

Rated operational current Ie		
Utilization category	Voltage (V)	Current (A)
AC-20A	800	32
AC-21A	20 - 690	32
AC-22A	20 - 690	32

Rated operational power				
Utilization category	Voltage (V)	No. of phases	No. of poles	Power (kW)
AC-3	220 - 240	3	3	5,50
AC-3	380 - 440	3	3	11
AC-3	500 - 500	3	3	11
AC-3	660 - 690	3	3	11
AC-3	110 - 120	1	2	1,50
AC-3	220 - 240	1	2	3
AC-3	380 - 440	1	2	5,50
AC-3	500 - 500	1	2	7,50
AC-3	660 - 690	1	2	8,50
AC-23A	220 - 240	3	3	9
AC-23A	380 - 440	3	3	16
AC-23A	500 - 500	3	3	20
AC-23A	660 - 690	3	3	22
AC-23A	110 - 120	1	2	2
AC-23A	220 - 240	1	2	4,20
AC-23A	380 - 440	1	2	7,50
AC-23A	500 - 500	1	2	9
AC-23A	660 - 690	1	2	9

Max. Fuse rating IEC		
Fuse characteristic	No. of Fuses	Current (A)
gG	1	35

UL60947-4-1, UL508

Rated insulation voltage Ui	
Voltage (V)	AC / DC
600	AC

Rated thermal current			
Current (A)	Ambient temperature (°C)	Additional Text	
30	0 - 40	--	

General Information
Text

- The operating handle and position indicating means to be used with these manual motor controllers should be provided from the manufacturer, or the operating handle and position indicating means to be used should have been previously evaluated in combination with the manual motor controllers.

GENERAL TECHNICAL INFORMATION
Tightening torque of screws

<i>tightening torque (Nm)</i>	<i>tightening torque (lb-in)</i>
1,20	10

Rated short-time withstand current Icw

<i>Time (s)</i>	<i>Current (A)</i>
1	850

Size of conductor

<i>composition of conductor</i>	<i>Min. / Max. value</i>	<i>No. of conductor per terminal</i>	<i>Cross section (mm²) or (AWG/kcmil)</i>	<i>Material of the wire</i>
Solid wire	Min.	1	0.5mm ²	Copper
Flexible wire	Min.	1	0.75mm ²	Copper
Flexible wire	Max.	1	6mm ²	Copper
Flexible wire	Max.	1	AWG 10	Copper
Single-core or stranded wire	Max.	1	10mm ²	Copper
Single-core or stranded wire	Max.	1	AWG 8	Copper
Flexible wire with sleeve	Max.	1	6mm ²	Copper
Flexible wire with ferrule according to DIN 46228	Min.	1	0.5mm ²	Copper

Approbations
Specification
Marking

CE marking


UK Directives

IEC 60947-3; EN 60947-3; VDE 0660 Teil107

IEC 60947-3
EN 60947-3

UL 60947-4-1; CSA C22.2 No. 60947-4-1


Power loss per pole

<i>Power (W)</i>
0,40

Conditions during transport and storing

<i>Minimum temperature (°C)</i>	<i>Maximum temperature (°C)</i>	<i>additional requirements</i>
-40	85	In case of temperatures below -5°C no shock load permissible

Shock / Vibration
Type of oscillation
Values
Resistance to vibration

IEC 61373 (1999) Category 1, Class B

General Information
Text

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.
- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
- After wiring, ALL terminal screws must be tightened to the specified torque values.
- The protection class of the selected mounting type may vary if optional extras are used.
- Do not lubricate or treat contacts.
- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.

Operating temperature

<i>Min. Temperature [°C]</i>	<i>Max. Temperature [°C]</i>
-5	55